



INSPECTOR'S CHECKLIST – ELECTRICAL SERVICE

Ohio Manufactured Homes Commission
5650 Blazer Parkway, Suite 100, Dublin, Ohio 43017
Phone: (614) 734-8454 • Fax: (614) 734-8531
Website: <http://www.omhc.ohio.gov/>

JOB ADDRESS: _____

DEALER: _____ CITY: _____ COUNTY: _____

INSTALLER: _____ LICENSE #: _____

SERIAL #: _____

INSTALLING ELECTRICIAN: _____ OCILB LICENSE IF ANY: _____

- 1) Yes ___ No ___ Overhead - Proper Cable, Mast, Support, Weatherhead, Point of Connection, Driploop.
- 2) Yes ___ No ___ Underground - Proper Riser, Bushings, Support.
- 3) Yes ___ No ___ Location of Service Equipment per Art 550.32 of the 2005 NEC OR (in the case of a used home) per Art. 550-23(a) Ex. #2 of 1993 NEC.
- 4) Yes ___ No ___ Service Equipment is Securely Fastened in Place.
- 5) Yes ___ No ___ Access Doors / Equipment Doors Will Open at Least 90 Degrees.
- 6) Yes ___ No ___ Clear Work Space in Front of Service Equipment.
- 7) Yes ___ No ___ Ground Rod, _____ Clamp, & _____ Grounding Electrode Conductor Properly Installed.
- 8) Yes ___ No ___ Equipment is Suitable for Use as Service Equipment.
- 9) Yes ___ No ___ Service Entrance Conductors are Properly Sized to Match Amperage.
- 10) Yes ___ No ___ Main Bonding Jumper Properly Sized and Installed.
- 11) Yes ___ No ___ All Connections are Tight and Made with Proper Conductor Bending Radius.
- 12) Yes ___ No ___ Main Disconnect Properly Labeled.
- 13) Yes ___ No ___ Back-fed Main Breakers are Secured in Place.

Note: Steel frame bonding jumper(s) may be inspected at this time if available. Yes ___ No ___ N/A ___

Note: Additional inspections by an Electrical Safety Inspector may be required if there are new circuits in basements, or other attached structures that were not delivered with the home.

REMARKS

Electrical Safety Inspector
(Signature)

Certification #

Date